

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7165-1130:182 Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Honeywell International Inc., 1500 W. Dundee Road, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3586

DESIGN: Models XLS1000, XLS200, XLS200R, XLS200-2 and XLS200R-2 fire alarm control units. Power limited. Suitable for automatic, manual, coded, noncoded, local, auxiliary, remote station, (DACT), (reverse polarity), proprietary, (multiplex), central station, waterflow, sprinkler supervisory and releasing service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

3-BPS/M, 3-BPS/M/230	Booster Power Supply
3-PPS/M, 3-PPS/M-230	Primary Power Supply
3-BBC/M, 3-BBC/M-230	Battery Booster Charger Power Supply
3-RS232	CPU RS232 Comm
3-XMEM	CPU Memory Option
3-IDC8/4	Zone Card
3-CPU, *3-CPU3	Central Processing Unit
3-LCD, *3-LCDXL	CPU LCD Display
3-OPS	Off Premises Signaling Module
3-LDSM	LED Display Module
3-LRMF	Blank LRM Filler
3-CHAS4, -CHAS-5, -CHAS-7	Module Chassis
XLS-CAB-5-R, 3-7(R), -14(R), -21(R)	Module Cabinet (red)
3-TAMP, 3-TAMP5	Tamper Switch
XLS-RCC7(R), -RCC14(R), -RCC21(R)	Closet Cabinet (red)
3-PSMON	Power Supply Drive Monitor
3-BPMON	Power Supply Booster Monitor
3-BBCMON	Battery Booster Charger Monitor
3-RS485a, 3-RS458B, 3-RS485R	Network Communication Card
3-24G,-24R,-24Y,-12RY,-12SY,-12SR,-12SG	LED Display
3-12/RY,-12/2Y,-12/2S2Y,-12/S1GY	LED Display
3-12/S1RY,-18S1G2Y,-6/3S1G2Y	LED Display
3-6/3S1GYR,-18S1GYR,-6/3S3L	LED Display
XLS200BR	Enclosure
3-SSDC, *3-SSDC1, *3-SDDC1	Single Loop Controller Module
3-SDC, *3-DSDC1	Signature Data Card
3-RS485	Network Card
3-DSDC	Dual Loop Controller Module
CDR-3	Coder Module
3-FIB, 3-FIBA	Fiber/Copper Data Com Module
*3-FIBMB	Fiber Optic Interface Card
3-AADC, *3-AADC1	Analog Addressable Com Module
3-ATPINT	ATPC Interface Module
3-REMICA, 3-REMICP	Remote Microphone

32003193
3-ZA90, 3-ZA20A, 3-ZA20B,
3-ZA40A, 3-ZA40B, *3-ZA95
XLS-ATCK
3-MODCOM, 3-MODCOMP
3-NSHM1, 3-NSHM2
3-SAC
32004129
32004871
14507714
XLS-REL

Printer Assembly
Zone Amplifiers
Zone Amplifiers
Attack Kit Cover for 3-RCC7R Cabinet
Modern Communication/Pager Interface
Modern Communication Cards
Security Access Control Module
High Security Interface Assembly
XLS Lan Interface Assembly
Singlmode to Multimode Fiber Optic Converter
Releasing Module

RATING: XLS1000, XLS200, XLS200-2, XLS200R, XLS200R-2: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: For Fire Alarm Verification Feature, the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1657:186 Formerly 7165-1591:186

*Rev. 11-03-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division